






















Fire symbols

-  Fire alarm call point
-  Green em door release call point and test key
-  Smoke detector
-  Heat detector
-  Fire blanket
-  Alarm sounder
-  Combined alarm sounder and smoke detector
- S12* Fire action notice
- S13* "Fire door keep closed" signage
- S14* "Fire door keep locked" signage
- S25* "Push bar to open" and "fire door keep clear" signage
- FD30S* 30min fire door with intumescent smoke seals
- FD60S* 60min fire door with intumescent smoke seals
- SC* Self closing device
- VP* Vision panel
- PB* Push bar ironmongery
-  3 hour self contained non-maintained luminaire
-  3 hour self contained and maintained luminaire with directional arrow where necessary
-  3 hour self contained and maintained external luminaire
-  Thumb turn door release - simple fastening
-  Mechanical heavy usage Digilock door release - simple fastening with dual backplate and hold open function
-  Xenon beacon unit with integral sounder to comply with the Equality Act 2010
-  Recessed/surface mounted fire alarm zone indicator/control panel
-  Magnetic door holder connected to fire alarm with fail safe release upon activation
-  Magnetic lock and fixing brackets with digital access control panel and push button release

-  Foam fire extinguisher
-  Carbon Dioxide fire extinguisher
-  Dry Powder fire extinguisher
-  9-litre water fire extinguisher
-  Wet chemical fire extinguisher

